



6 May 2014

(14-2744)

Page: 1/1

Committee on Technical Barriers to Trade

Original: English

NOTIFICATION

Addendum

The following communication, dated 1 May 2014, is being circulated at the request of the delegation of Egypt.

Products covered: Room air conditioners

This addendum concerns the change to Egyptian standard ES 4814 /2013 "Non-ducted air conditioners and heat pumps – Testing and rating for performance" which was formerly mandated by Ministerial Decree No. 589/2005.

The producers and importers must comply with the requirements prescribed in the Egyptian standard ES 4814 /2013, which is adopted, hence identical to ISO 5151/2010.

ES 4814 specifies the standard conditions for capacity and efficiency ratings of non-ducted air-cooled air conditioners and non-ducted air-to-air heat pumps. It is applicable to ducted units rated at less than 8 kW and intended to operate at an external static pressure of less than 25 Pa. also specifies the test methods for determining the capacity and efficiency ratings.

Producers and importers are kept informed of any amendments in the Egyptian standards through the publication of administrative orders in the official gazette.

Agency or authority designated to handle comments and text available from: National enquiry point

Egyptian Organization for Standardization and Quality
16 Tadreeb El-Modarrebeen St., Ameriya, Cairo - Egypt
E-mail: moi@idsc.net.eg/tbteos@eos.org.eg
Website: <http://www.eos.org.eg>
Tel.: 0222845528
Fax: 0222845504
